

## SECTION 009113 – ADDENDUM TWO

## PART 1 - ADDENDA

## 1.1 PROJECT INFORMATION

- A. Project Name: 22089 Newton Municipal Schools ESSER 3
- B. Owner: Newton Municipal School District
- C. Architect: Dale | Bailey, an Association
- D. Architect Project Number: 22089
- E. Date of Addendum Two: 13 June 2023

## 1.2 NOTICE TO BIDDERS

- A. This Addendum is issued to all registered plan holders pursuant to the Instructions to Bidders and Conditions of the Contract. This Addendum serves to clarify, revise, and supersede information in the Project Manual, Drawings, and previously issued Addenda. Portions of the Addendum affecting the Contract Documents will be incorporated into the Contract by enumeration of the Addendum in the Owner/Contractor Agreement.
- B. The Bidder shall acknowledge receipt of this Addendum in the appropriate space on the Bid Form.
- C. The date for receipt of bids is unchanged by this Addendum at same time and location.

## 1.3 GENERAL RESPONSES TO REQUESTS FOR INFORMATION

- A. Question: Door schedule (A611) calls for exterior Doors 213A, 213B, 301A, and 301B to be 45-min fire rated. Do you want fire rated glazing in these exterior doors.  
Answer: Doors 213A, 213B, and 301B are incorrectly labeled as fire rated as they are exterior doors. 301A, which used to be an exterior door, has been encapsulated in a hallway and will need to be fire rated, the glazing can be fire rated with rated wire glass.
- B. Question: Is there an existing EMS system to tie controls into. BACnet thermostats are mentioned in the specs. It appears to be zoned for individual thermostat control. Please clarify.  
Answer: There is no existing EMS and no need for Bacnet on this job. Mention in specs will be removed by this addendum.

1.4 REVISIONS TO SPECIFICATIONS

- A. Section 230670 – PACKAGED AIR CONDITIONS. (Not Reissued).
  - 1. Delete paragraph 2.1.L.1. Bacnet communication card not required.

1.5 REVISIONS TO DRAWINGS

- A. Sheet M-201 – Mechanical Schedules (Not Reissued).
  - 1. Self-Contained Packaged Unit Schedule – Remove Feature/Accessories #13. Bacnet communication card not required.

1.6 ATTACHMENTS

- A. None.

END OF ADDENDUM TWO