

## SECTION 009113 – ADDENDUM FOUR

## PART 1 - ADDENDA



## 1.1 PROJECT INFORMATION

- A. Project Name: 23087 Clinton Reroofing Project
- B. Owner: Clinton Public School District, 201 Easthaven Drive, Clinton, MS 39060.
- C. Architect: Dale | Bailey, an Association, One Jackson Place, Suite 250, 188 East Capitol Street, Jackson, MS 39201.
- D. Architect Project Number: 23087
- E. Date of Addendum Four: 23 February 2024

## 1.2 NOTICE TO BIDDERS

- A. This Addendum is issued to all registered plan holders pursuant to the Instructions to Bidders and Conditions of the Contract. This Addendum serves to clarify, revise, and supersede information in the Project Manual, Drawings, and previously issued Addenda. Portions of the Addendum affecting the Contract Documents will be incorporated into the Contract by enumeration of the Addendum in the Owner/Contractor Agreement.
- B. The Bidder shall acknowledge receipt of this Addendum in the appropriate space on the Bid Form.
- C. The date for receipt of bids is unchanged by this Addendum at same time and location.

## 1.3 GENERAL RESPONSES TO REQUESTS FOR INFORMATION

- A. Question: Where will the roofing membrane start and stop? Will it terminate at the counter flashing or extend further? I have attached a picture for reference.  
Answer: Extend over 5'.
- B. Question: Can you provide a copy of the roof scans.  
Answer: We do not have roof scans.
- C. Question: We have already ordered our Bid Bonds for each individual school and it will be too late to order new ones. Will Bid Bonds for each individual school be acceptable?  
Answer: Bid bond for individual schools will be acceptable.
- D. Question: Are we to replace the copper with copper at the Clinton r. HS or will a different material be acceptable?  
Answer: Replace with copper.

1.8 ATTACHMENTS

- A. None.

END OF ADDENDUM FOUR