

PART 1 - CLARIFICATION

1.1 PROJECT INFORMATION

- A. Project Name: 21098.01 New Albany Center for Innovation Phase 1
- B. Owner: New Albany Schools, 1112 Wesson Tate Drive, Mississippi 38652.
- C. Architect: Dale | Bailey, An Association, One Jackson Place, Suite 250, 188 East Capitol Street, Jackson, MS 39201.
- D. Architect Project Number: 21098.01
- E. Date of Clarification: 28 February 2023

1.2 CLARIFICATIONS

- A. QUESTION: On the plans and details there is no specification for the size of the water meter on the 3" domestic line. The domestic line is 3" but the only detail is a typical service (normally ¾" or 1") and it does not specify a meter size. According to my supplier, if the meter is a 3", then it will need a concrete vault, valve and flanged spool pieces, which is not shown on the detail provided. Please advise on the meter size and details.

ANSWER: A 3" Water Meter will be required for the 3" service line, with the meter being installed as per manufacturer's recommendations.

END OF CLARIFICATION